



JABATAN AIR NEGERI SABAH

Butiran Pendaftaran

No Sijil : JANS.24.75

Nama Pembekal : **GLOBAL TANKCOM SDN BHD**
Suite 2-7-5, No.2,7th Floor, Wisma Manjalara, Jalan 7A/62A, Bandar Manjalara,
52200 Kuala Lumpur

Nama Pembuat /
Pengilang : **TANGSHAN YINGHERUI ENVIRONMENTAL EQUIPMENT CO. LTD**
Emerging Industrial Park, Caofeidian Industrial District, Tangshan City, Heibei
Province, People's Republic Of China

Nama Prinsipal /
Pemilik : **TANGSHAN YINGHERUI ENVIRONMENTAL EQUIPMENT CO. LTD**
Emerging Industrial Park, Caofeidian Industrial District, Tangshan City, Heibei
Province, People's Republic Of China

Nama Produk : Glass Fused Steel Tank

Kategori : A [Storage of Water]

Kelas/Saiz/Model : (Sila rujuk Jadual di muka surat belakang)

Jenama : **YHR**

Piawaian : MAUFACTURER'S STANDARD / ISO 287 65 : 2016

Tarikh dikeluarkan : 28 Mei 2024

Sah sehingga : 28 Mei 2026

Perihal produk :

| NAMA PRODUK | MODEL | SIRI | PERIHAL/CLASS/SAIZ |
|-------------------------------|--|------------------------|--|
| Glass Fused Steel Bolted Tank | GLASS COATED / GLASS LINED / GLASS FUSED / EPOXY C | STORAGE CISTERN / TANK | STEEL TANK WITH LINING OR COATING (GLASS COATED/GLASS LINING/EPOXY COATED/EPOXY LINING/HDPE LINING) 1. MAXIMUM CAPACITY ALLOWED FOR ELEVATED TANK IS 500 000 G AND FOR GROUND STORAGE IS 750 000 G. 2. MAXIMUM HEIGHT ALLOWED IS 5 METER OR 4 PANELS OR WHICH ONE IS LOWER. 3. TANK MUST BE SUPPLIED AND INSTALLED BY THE SAME SUPPLIER OR INSTALLER WHO IS APPOINTED BY SUPPLIER. 4. MINIMUM 10 YEARS WARRANTY PERIOD FOR TANK AND SEALANT/LINING IS REQUIRED. 5. ALL STAINLESS STEEL ACCESSORIES (NOZZLES, FLANGE, MANWAYS, LADDERS, BRACKETS, ETC) THAT COME IN DIRECT CONTACT WITH EPOXY PANELS NEED TO HAVE APPLIED AN ELASTIC, 1-COMPONENT SEALANT WITH A POLYURETHANE BASE. (SPECIALLY DESIGNED FOR SEALING TANKS BUILD IN SECTION) COAT THE ENTIRE STAINLESS STEEL MOUNTING AREA WHERE IT WILL ATTACH TO THE EPOXY COATED STEEL. |
| | not applicable | not applicable | Glass Fused Steel (GFS) Bolted Tank Capacity from 41m ³ to 20,228m ³ |