



JABATAN AIR NEGERI SABAH

Butiran Pendaftaran

No Sijil : JANS.2025.21

Nama Pembekal : **AEG SDN BHD**
No 7 Jalan Pemberita U1/49, Temasya Industrial Park,
40150 Glenmarie, Shah Alam, Selangor

Nama Pembuat /
Pengilang : **SUNTEN ELECTRIC EQUIPMENT CO LTD**
No 23, Xinyue Road, Wusha Community, Daliang Subdistrict, Shunde District, Foshan
City, 528300 Guangdong Province, P.R China

Nama Prinsipal /
Pemilik : **SUNTEN ELEKTRIK MALAYSIA SDN BHD**
No 46, Taman Maju Kota, Lorong Burung Ruai, Jalan Tuaran,
88450 Kota Kinabalu, Sabah

Nama Produk : Sunten Dry Cast Transformer

Kategori : B [Water Quality Equipment]

Kelas/Saiz/Model : (Sila rujuk Jadual di muka surat belakang)

Jenama : **SUNTEN**

Piawaian : IEC 60076-11:2004

Tarikh dikeluarkan : 20 Februari 2025

Sah sehingga : 20 Februari 2027

Perihal produk :

NAMA PRODUK	MODEL	SIRI	PERIHAL/KELAS/SAIZ
SUNTEN DRY CAST TRANSFORMER	SC10- 300/11/0.433		RATED POWER (KvA): 300; NO-LOAD LOSS (W): 400; LOAD LOSS (AT 120 C)(W): 2800; TOTAL LOSSES (W): 3200; IMPEDANCE (AT 120 C)(%):4
	SC10- 500/11/0.433		RATED POWER (KvA): 500; NO-LOAD LOSS (W): 800; LOAD LOSS (AT 120 C)(W): 4100; TOTAL LOSSES (W): 4900; IMPEDANCE (AT 120 C)(%):4
	SC10- 750/11/0.433		RATED POWER (KvA): 750; NO-LOAD LOSS (W): 1000; LOAD LOSS (AT 120 C)(W): 6000; TOTAL LOSSES (W): 7000; IMPEDANCE (AT 120 C)(%):4

No Sijil : JANS.2025.21
Perihal :

	SC10-1000/11/0.433		RATED POWER (KvA): 1000; NO-LOAD LOSS (W): 1200; LOAD LOSS (AT 120 C)(W): 7000; TOTAL LOSSES (W): 8200; IMPEDANCE (AT 120 C)(%):6
	SC10-1250/11/0.433		RATED POWER (KvA): 1250; NO-LOAD LOSS (W): 1880; LOAD LOSS (AT 120 C)(W): 8200; TOTAL LOSSES (W): 10080; IMPEDANCE (AT 120 C)(%):6
	SC10-1600/11/0.433		RATED POWER (KvA): 1600; NO-LOAD LOSS (W): 2300; LOAD LOSS (AT 120 C)(W): 10300; TOTAL LOSSES (W): 12600; IMPEDANCE (AT 120 C)(%):6
	SC10-2000/11/0.433		RATED POWER (KvA): 2000; NO-LOAD LOSS (W): 2900; LOAD LOSS (AT 120 C)(W): 13000; TOTAL LOSSES (W): 15900; IMPEDANCE (AT 120 C)(%):6

FOR WEBSITE VIEW ONLY