



JABATAN AIR SABAH

Butiran Pendaftaran

No Sijil : **JANS.2026.68a**

Nama Pembekal : **STEELWORKS ENGINEERING SDN BHD**
Lot 3, Jalan CJ5, Kawasan Perindustrian Cheras Jaya,
43200 Belakong, Selangor.

Nama Pengilang : **STEELWORKS ENGINEERING SDN BHD**
Lot 3, Jalan CJ5, Kawasan Perindustrian Cheras Jaya,
43200 Belakong, Selangor.

Nama Prinsipal /
Pemilik : **STEELWORKS ENGINEERING SDN BHD**
Lot 3, Jalan CJ5, Kawasan Perindustrian Cheras Jaya,
43200 Belakong, Selangor.

Nama Produk : Stainless Steel Sectional Panel Tank

Kategori : A - Storage Of Water

Kelas/Saiz/Model : (Sila rujuk Jadual di muka surat belakang)

Jenama : **SUNNIK**

Piawaian : SANS 10329 : 2020 EDITION 1.4

Tarikh Dikeluarkan : 12 Ogos 2026

Sah Sehingga : 12 Ogos 2028

Perihal Produk :

NAMA PRODUK	MODEL	SIRI	PERIHAL/CLASS/SAIZ
PRESSED STEEL SECTIONAL RECTANGULAR WATER TANK	NOMINAL SIZE OF PANEL (mm): 1220 x 1220	NA / MATERIAL: MILD STEEL; FINISHING: HOT-DIP GALVANIZ ED	TYPE 1 AND TYPE 2 / DEPTH OF TANK: LESS THAN OR EQUAL TO 1220MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 2440MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 POSITION OF PLATES: TOP TIERS OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 3660MM; POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: SECOND AND TOP TIERS OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 4880MM. POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 6.0 POSITION OF PLATES: SECOND TIER OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: THIRD AND TOP TIERS OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 1220MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 2440MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 POSITION OF PLATES: TOP TIERS OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 3660MM; POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: SECOND AND TOP TIERS OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 4880MM. POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 6.0 POSITION OF PLATES: SECOND TIER OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: THIRD AND TOP TIERS OF SIDES AND ENDS, MINIMUM THICKNESS (MM): 3.0

No Sijil : JANS.2026.68b

Perihal :

NAMA PRODUK	MODEL	SIRI	PERIHAL/CLASS/SAIZ
PRESSED STEEL SECTIONAL RECTANGULAR WATER TANK	NOMINAL SIZE OF PANEL (mm): 1000 x 1000	NA / MATERIAL: MILD STEEL; FINISHING: HOT-DIP GALVANIZED	TYPE 1 AND TYPE 2 / DEPTH OF TANK: LESS THAN OR EQUAL TO 1000MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 2000MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 POSITION OF PLATES: TOP TIERS OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 3000MM; POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: SECOND TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 POSITION OF PLATES: TOP TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 4000MM; POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 5.0 POSITION OF PLATES: SECOND TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: THIRD AND TOP TIERS OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 / DEPTH OF TANK: LESS THAN OR EQUAL TO 1000MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 2000MM; POSITION OF PLATES: BOTTOMS, SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 POSITION OF PLATES: TOP TIERS OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 3000MM; POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: SECOND TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 POSITION OF PLATES: TOP TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0 DEPTH OF TANK: LESS THAN OR EQUAL TO 4000MM. POSITION OF PLATES: BOTTOMS, FIRST TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 5.0 POSITION OF PLATES: SECOND TIER OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 4.5 POSITION OF PLATES: THIRD AND TOP TIERS OF SIDES AND ENDS; MINIMUM THICKNESS (MM): 3.0